



# ASHRAE

*Technology for a Better Environment*

1791 Tullie Circle, NE • Atlanta, Georgia 30329-2305 USA • Tel 404.636.8400 • Fax 404.321.5478 • <http://www.ashrae.org>

Douglas K. Tucker, P.E.  
*Assistant Manager of Standards - International*

E-mail [dtucker@ashrae.org](mailto:dtucker@ashrae.org)

May 14, 2007

To Whom It May Concern:

This letter confirms that the blend R-32/125/143a/134a (15.0/25.0/10.0/50.0 mass percent) with tolerances of ( $\pm 2.0\%/\pm 2.0\%/\pm 2.0\%/\pm 2.0\%$ ) has been given the designation R-427A and assigned a safety classification of A1.

The application for this blend was submitted by Arkema and given the application designation R0008-06-05. This blend was included in addendum j to ANSI/ASHRAE Standard 34-2004. The first public review of this addendum was held from September 22, 2006 to October 22, 2006. No comments were received and the addendum was approved by the ASHRAE Standards Committee on January 27, 2007, by the ASHRAE Board of Directors on March 2, 2007 and by the American National Standards Institute on March 3, 2007.

R-427A is included in ANSI/ASHRAE Standard 34-2007.

Please contact me if you have any questions.

Best regards,

Douglas K. Tucker